

Total Trihalomethanes MCL Template

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

EJ Water SangChris Has Levels of Total Trihalomethanes Above Drinking Water Standards

Our water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Testing results we received on 07/1/2024-9/30/2024 show that our system exceeds the standard, or maximum contaminant level (MCL), for total trihalomethanes (TTHMs). The standard for TTHMs is 0.080 milligrams per liter (mg/L). The average level of TTHMs over the last year was 0.085 MG/L.

What should I do?

- **You do not need to use an alternative (e.g., bottled) water supply.** However, if you have specific health concerns, consult your doctor.

What does this mean?

This is not an immediate risk. If it had been, you would have been notified immediately. *However, some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.*

What happened? What is being done?

While the annual average was exceeded, the most recent results show THM levels to be below the standard. Routine flushing to prevent water age is being conducted, and we anticipate resolving the problem immediately.

For more information, please contact Jacob Durbin at 217-925-5566 or 108 S. Main St., PO Box 8 Beecher City, IL 62424.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by EJ
Water SangChris

Water System ID#

IL1670230

Date distributed

12/20/2024