

# Consumer Confidence Report

## Annual Drinking Water Quality Report

DIETERICH

IL0490150

Annual Water Quality Report for the period of January 1 to December 31, 2024

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

The source of drinking water used by DIETERICH is Purchased Surface Water

For more information regarding this report contact:

Name Brad Hardiek

Phone 217-925-5410

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.

Source of Drinking Water	Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.
The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.	In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.
Contaminants that may be present in source water include: - Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.  - Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.  - Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.  - Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.  - Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.	Some people may be more vulnerable to contaminants in drinking water than the general population.  Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).  Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The drinking water supplier is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standard Institute accredited certifier

to reduce lead in drinking water. If you are concerned about lead in your water, you may wish to have your water tested, contact **Brad Hardiek** at 217-925-5410. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Source Water Information

Source Water Name		Type of Water	Report Status	Location
CC01 - EJ WATER CONNECTION FOR	EJ WATER CONNECTION FOR	SW	_____	_____

## Source Water Assessment

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings. The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please stop by City Hall or call our water operator at 217-925-5410. To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

Source of Water: E J WATER CORP To determine E J Water Corporation's susceptibility to groundwater contamination, the Illinois EPA reviewed a Well Site Survey, published in 1996 by the Illinois EPA, a Source Water Protection Management Plan, prepared by the facility's planning committee and published in 1997, and a survey of the south well field performed in 2005. Based on the above documents, the community water supply's source water is susceptible to IOC and SOC contamination from non-point sources related to agricultural land use, although no presence of any pesticides/herbicides were detected in any water samples thus far analyzed. As a result of monitoring conducted at the wells and entry point to the distribution system, the land use activities, and source water protection initiatives by the facility, the E J Water Corporation's groundwater source is not susceptible to VOC contamination. However, Illinois EPA considers all surface water sources of public water supply to be susceptible to potential pollution problems. Hence the reason for mandatory treatment of all public water supplies in Illinois. Mandatory treatment includes coagulation, sedimentation, filtration and disinfection.

Dieterich

**Coliform Bacteria**

Maximum Contaminant Level Goal	Total Coliform Maximum Contaminant Level	Highest No. of Positive	Fecal Coliform or E. Coli Maximum Contaminant Level	Total No. of Positive E. Coli or Fecal Coliform Samples	Violation	Likely Source of Contamination
0	1 positive monthly sample.	1		0	N	Naturally present in the environment.

**Lead and Copper**

Definitions:

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Copper Range: <3.0 ug/l to 78 ug/lLead Range: <1.0 ug/l to 20 ug/lTo obtain a copy of the system's lead tap sampling data: Brad Hardiek 217-925-5410CIRCLE ONE: Our Community Water Supply has has not developed a service line material inventory.To obtain a copy of the system's service line inventory: 217-925-5410

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	06/21/2022	1.3	1.3	0.055	0	ppm	N	Corrosion of household plumbing systems; Erosion of natural deposits.
Lead	06/21/2022	0	15	2.7	1	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

**Water Quality Test Results**

Definitions:

The following tables contain scientific terms and measures, some of which may require explanation.

Avg:

Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment:

A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Dieterich

Water Quality Test Results

Level 2 Assessment:	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum residual disinfectant level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum residual disinfectant level goal or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
na:	not applicable.
mrem:	millirems per year (a measure of radiation absorbed by the body)
ppb:	micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm:	milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	2024	1.5	1.4 - 1.6	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.
Haloacetic Acids (HAA5)	2024	14	10.03 - 13.65	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2024	31	17.8 - 31.4	No goal for the total	80	ppb	N	By-product of drinking water disinfection.

**Coliform Bacteria**

Maximum Contaminant Level Goal	Total Coliform Maximum Contaminant Level	Highest No. of Positive	Fecal Coliform or E. Coli Maximum Contaminant Level	Total No. of Positive E. Coli or Fecal Coliform Samples	Violation	Likely Source of Contamination
0	1 positive monthly sample.	1		0	N	Naturally present in the environment.

**Lead and Copper**

Definitions:

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Copper Range: < 3.0 ug/l to 530 ug/lLead Range: < 1.0 ug/l to 13 ug/lTo obtain a copy of the system's lead tap sampling data: Jared Runde (217) 925-5566CIRCLE ONE: Our Community Water Supply has/has not developed a service line material inventory.To obtain a copy of the system's service line inventory: 217-925-5566

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2024	1.3	1.3	0.39	0	ppm	N	Corrosion of household plumbing systems; Erosion of natural deposits.
Lead	2024	0	15	8	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

**Water Quality Test Results**

Definitions:

The following tables contain scientific terms and measures, some of which may require explanation.

Avg:

Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment:

A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.



Water Quality Test Results

Level 2 Assessment:	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum residual disinfectant level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum residual disinfectant level goal or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
na:	not applicable.
mrem:	millirems per year (a measure of radiation absorbed by the body)
ppb:	micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm:	milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.

**Regulated Contaminants**

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	2024	1.7	1 - 2	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.
Chlorite	2024	0.78	0.11 - 0.78	0.8	1	ppm	N	By-product of drinking water disinfection.
Haloacetic Acids (HAA5)	2024	26	1.05 - 34.5	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2024	44	12.5 - 43.9	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	2024	0.0017	0.0017 - 0.0017	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	2024	0.5	0.499 - 0.499	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Mercury	2024	0.5	0.52 - 0.52	2	2	ppb	N	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from cropland.
Nitrate [measured as Nitrogen]	2024	0.23	0.08 - 0.23	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Sodium	2024	15	15 - 15			ppb	N	Erosion from naturally occurring deposits. Used in water softener regeneration.
Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	07/07/2021	0.189	0.189 - 0.189	0	5	pCi/L	N	Erosion of natural deposits.
Synthetic organic contaminants including pesticides and herbicides	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Atrazine	2024	0.71	0 - 0.71	3	3	ppb	N	Runoff from herbicide used on row crops.

Simazine	2024	0.44	0 - 0.44	4	4	ppb	N	Herbicide runoff.
----------	------	------	----------	---	---	-----	---	-------------------

**Turbidity**

	Limit (Treatment Technique)	Level Detected	Violation	Likely Source of Contamination
Highest single measurement	1 NTU	0.22 NTU	N	Soil runoff.
Lowest monthly % meeting limit	0.3 NTU	100%	N	Soil runoff.

Information Statement: Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration system and disinfectants.

**Total Organic Carbon**

The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set, unless a TOC violation is noted in the violations section.

## Violations Table

Chlorite			
Some infants and young children who drink water containing chlorite in excess of the MCL could experience nervous system effects. Similar effects may occur in fetuses of pregnant women who drink water containing chlorite in excess of the MCL. Some people may experience anemia.			
Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE (DBP), MAJOR	11/01/2024	11/30/2024	The original sample was rejected by the laboratory due to exceeding the required hold time. A re-sample was not submitted within the necessary time frame. However, subsequent samples were satisfactory, and there is no indication of a water quality issue during the period in question.

Cryptosporidium			
Gastrointestinal illness (e.g., diarrhea, vomiting, cramps).			
Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, SOURCE (LT2), MAJOR	08/01/2024	08/31/2024	The laboratory did not initially provide a complete sample kit, which delayed testing. Once the complete kit was received, sampling was conducted and the results were satisfactory. There is no indication of a water quality issue during the period in question.
MONITORING, SOURCE (LT2), MAJOR	09/01/2024	09/30/2024	The laboratory did not initially provide a complete sample kit, which delayed testing. Once the complete kit was received, sampling was conducted and the results were satisfactory. There is no indication of a water quality issue during the period in question.
MONITORING, SOURCE (LT2), MAJOR	10/01/2024	10/31/2024	The laboratory did not initially provide a complete sample kit, which delayed testing. Once the complete kit was received, sampling was conducted and the results were satisfactory. There is no indication of a water quality issue during the period in question.
MONITORING, SOURCE (LT2), MAJOR	11/01/2024	11/30/2024	The laboratory did not initially provide a complete sample kit, which delayed testing. Once the complete kit was received, sampling was conducted and the results were satisfactory. There is no indication of a water quality issue during the period in question.

E. coli			
Fecal coliforms and E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young			
Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, SOURCE (LT2), MAJOR	08/01/2024	08/31/2024	The laboratory did not initially provide a complete sample kit, which delayed testing. Once the complete kit was received, sampling was conducted and the results were satisfactory. There is no indication of a water quality issue during the period in question.
MONITORING, SOURCE (LT2), MAJOR	09/01/2024	09/30/2024	The laboratory did not initially provide a complete sample kit, which delayed testing. Once the complete kit was received, sampling was conducted and the results were satisfactory. There is no indication of a water quality issue during the period in question.
MONITORING, SOURCE (LT2), MAJOR	10/01/2024	10/31/2024	The laboratory did not initially provide a complete sample kit, which delayed testing. Once the complete kit was received, sampling was conducted and the results were satisfactory. There is no indication of a water quality issue during the period in question.
MONITORING, SOURCE (LT2), MAJOR	11/01/2024	11/30/2024	The laboratory did not initially provide a complete sample kit, which delayed testing. Once the complete kit was received, sampling was conducted and the results were satisfactory. There is no indication of a water quality issue during the period in question.

## Violations Table

MONITORING, SOURCE (LT2), MAJOR	12/01/2024	12/31/2024	The laboratory did not initially provide a complete sample kit, which delayed testing. Once the complete kit was received, sampling was conducted and the results were satisfactory. There is no indication of a water quality issue during the period in question.
---------------------------------	------------	------------	---

### Total Trihalomethanes (TTHM)

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE (DBP), MAJOR	07/01/2024	09/30/2024	The original sample was rejected by the laboratory due to exceeding the required hold time. A re-sample was not submitted within the necessary time frame. However, subsequent samples were satisfactory, and there is no indication of a water quality issue during the period in question.

### Turbidity

Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, SOURCE (LT2), MAJOR	08/01/2024	08/31/2024	The laboratory did not initially provide a complete sample kit, which delayed testing. Once the complete kit was received, sampling was conducted and the results were satisfactory. There is no indication of a water quality issue during the period in question.
MONITORING, SOURCE (LT2), MAJOR	09/01/2024	09/30/2024	The laboratory did not initially provide a complete sample kit, which delayed testing. Once the complete kit was received, sampling was conducted and the results were satisfactory. There is no indication of a water quality issue during the period in question.
MONITORING, SOURCE (LT2), MAJOR	10/01/2024	10/31/2024	The laboratory did not initially provide a complete sample kit, which delayed testing. Once the complete kit was received, sampling was conducted and the results were satisfactory. There is no indication of a water quality issue during the period in question.
MONITORING, SOURCE (LT2), MAJOR	11/01/2024	11/30/2024	The laboratory did not initially provide a complete sample kit, which delayed testing. Once the complete kit was received, sampling was conducted and the results were satisfactory. There is no indication of a water quality issue during the period in question.
MONITORING, SOURCE (LT2), MAJOR	12/01/2024	12/31/2024	The laboratory did not initially provide a complete sample kit, which delayed testing. Once the complete kit was received, sampling was conducted and the results were satisfactory. There is no indication of a water quality issue during the period in question.